

CITY OF ST. LOUIS  
DEPARTMENT OF PUBLIC SAFETY  
COMMISSIONER'S OFFICE  
CITY HALL - ROOM 426

FACSIMILE TRANSMITTAL SHEET

TO: LARRY KAPLAN FROM: JOHN McDONALD  
COMPANY: DATE: 11-19-07  
FAX NUMBER: 863-9777 TOTAL NO. OF PAGES INCLUDING COVER: 11  
PHONE NUMBER: SENDER'S REFERENCE NUMBER:  
RE: YOUR REFERENCE NUMBER:

URGENT  FOR REVIEW  PLEASE COMMENT  PLEASE REPLY  PLEASE RECYCLE

OFFICE: (314) 622-3318

FAX: (314) 622-3235

CITY OF ST. LOUIS  
DEPARTMENT OF PUBLIC SAFETY  
COMMISSIONER'S OFFICE  
CITY HALL - ROOM 426

FACSIMILE TRANSMITTAL SHEET

TO:	CRAIG HELLER	FROM:	JOHN McDONALD
COMPANY:		DATE:	11-18-07
FAX NUMBER:	241-6702	TOTAL NO. OF PAGES INCLUDING COVER:	11
PHONE NUMBER:		SENDER'S REFERENCE NUMBER:	
RE:		YOUR REFERENCE NUMBER:	

URGENT     FOR REVIEW     PLEASE COMMENT     PLEASE REPLY     PLEASE RECYCLE

Craig,

The cabinet lighting is in violation of City Ordinance 65020, Section E-106-2, Section E-114-2, Section E-114-1.2 and Section E-107-2.

The ordinance adopts the National Electrical Code, 1999 edition. The cabinet lighting is in violation of Section 90-2 (a), Section 400-8 and Section 400-9.

The City Ordinance and the National Electrical Code apply to all electrical wiring and devices, regardless of the voltage used.

For the 9<sup>th</sup> floor in which the cabinets are installed there are two options to correct the violations.

- 1) Employ an electrical contractor licensed by the City to obtain a permit to install the lighting such that it meets all codes as required by the City.
- 2) Employ a qualified design professional to verify that the lighting is installed to meet all codes as required by the City.

An electrical contractor licensed by the City is required to install the lighting in all cabinets not installed in the building.

---